

TAMWORTH MONITORING DATA

Licensee: Downer Edi Works Pty Ltd	Address: 15-27 Armstrong St Tamworth NSW 2340	EPL No. 12118
Sampling Point: Outlet Point 2		Published: May 2018

Stormwater Monitoring Results						
Date Sampled	Report Obtained	Suspended Solids (mg/L)	Suspended Solids Discharge Limit (mg/L)	Oil & Grease (mg/L)	Oil & Grease Discharge Limit (mg/L)	Comments
12/10/17	26/10/17	15	50	<10	10	Test complies with discharge limits.

