

TAMWORTH MONITORING DATA

Licensee:	Downer Edi Works Pty Ltd	Address:	15-27 Armstrong St Tamworth NSW 2340	EPL No.	12118
		Obtained:	27/02/2015	Published:	27/03/15

Sampling Point	Monitoring frequency as per licence	Pollutant	Result	Discharge Limit	Unit
Outlet Point 2	Discharge after bypass of first flush system.	Suspended Solids	25	50	mg/L
Outlet Point 2	Discharge after bypass of first flush system.	Oil & Grease	< 10	10	mg/L

Comment

The water discharge complies with the Environmental Protection Licence.

